

As of 6/24/2024

APCo Dist Queue #	Fuel Type	Capacity (MW)	Substation/Transformer	Circuit	Date of Submission of Final	Interdependency Status	Project Status	Date of Final Executed SGIA
Pre-Queue	Water	1.2 MW	Haysi/ 69-12.47 kV, 20 MVA	Bartlick 12.47 kV	7/7/2014		Withdrawn	
APCo_VA_00100	Water	.622 MW	Schuyler/46-12.47 kV, 2 MVA	Schuyler 12.47 kV	9/3/2014	A	Active	6/11/2015
APCo_VA_00101	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	8/13/2015	A	In Service	9/16/2020
APCo_VA_00102	Solar	10 MW	Franklin/138-12.47 kV, 22.4 MVA	Grassy Hill 12.47 kV	12/3/2015, 11:06 AM		Withdrawn	
APCo_VA_00103	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	12/3/2015, 2:46 PM		Withdrawn	
APCo_VA_00104	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Plum Creek 12.47 kV	12/4/2015, 11:59 AM		Withdrawn	
APCo_VA_00105a	Solar	1 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	5/17/2016		In Service	12/5/2016
APCo_VA_00105b	Solar	10 MW	Franklin/138-12.47 kV, 22.4 MVA	Grassy Hill 12.47 kV	2/6/2017, 11:57 AM		Withdrawn	
APCo_VA_00106	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	2/8/2017, 1:00 PM		Withdrawn	
APCo_VA_00107	Solar	10 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/22/2017, 10:52 AM	A	In Service	9/16/2020
APCo_VA_00108	Solar	18.4 MW	Peak Creek/138-34.5 kV, 30 MVA or	Not determined	2/24/2017, 9:51 AM		Withdrawn	
APCo_VA_00109	Solar	20 MW	Rural Retreat/138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 9:52 AM		Withdrawn	
APCo_VA_00110	Solar	10 MW	Blaine/138-34.5 kV, 30 MVA	Wirtz 34.5 kV	2/24/2017, 12:18 PM		Withdrawn	
APCo_VA_00111	Solar	15 MW	Progress Park/138-34.5 kV, 30MVA	Progress Park or Mabetown	2/24/2017, 12:18 PM		Withdrawn	
APCo_VA_00112	Solar	10 MW	Redwood /138-12.47 kV, 20 MVA	Truevine 12.47 kV	2/24/2017, 12:20 PM		Withdrawn	
APCo_VA_00113	Solar	10 MW	Blaine/138-34.5 kV, 30 MVA	Burnt Chimney 34.5 kV	2/24/2017, 12:20 PM		Withdrawn	
APCo_VA_00114	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/24/2017, 12:22 PM		Withdrawn	
APCo_VA_00115	Solar	10 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/24/2017, 12:22 PM		Withdrawn	
APCo_VA_00116	Solar	5 MW	Buckhorn/138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	2/24/2017, 2:17 PM		Withdrawn	
APCo_VA_00117	Solar	5 MW	Not determined	Not determined	2/24/2017, 2:17 PM		Withdrawn	
APCo_VA_00118	Solar	10 MW	Not in APCo service territory	Not in APCo service territory	2/24/20017, 3:28 PM		Withdrawn	
APCo_VA_00119	Solar	5 MW	Rural Retreat /138-34.5 kV/25 MVA	Groseclose 34.5 kV	2/24/2017, 3:49 PM		Withdrawn	
APCo_VA_00120	Solar	5 MW	Rural Retreat/138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00121	Solar	10 MW	Wythe/138-34.5 kV, 25 or 35 MVA	Not determined	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00122	Solar	6 MW	Rural Retreat / 138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00123	Solar	20 MW	Edgemont/138-12.47 kV, 22.4 MVA	Not determined	2/24/2017, 6:11 PM		Withdrawn	
APCo_VA_00124	Nat. Gas	1.43 MW	V.A. Hospital/34.5-4 kV, 10 MVA	34.5 kV Sub transmission loc	4/17/2017	A	Active	
APCo_VA_00125	Solar	20 MW	Stockton/ 138-34.5 kV, 30 MVA	Sandy River 34.5 kV	11/16/2016		In-Service	9/23/2020
APCo_VA_00126	Solar	15 MW	Lynbrook/138-12 kV, 20 MVA	Will require 2 POIs, undeter	Request from PJM to study		Withdrawn	
APCo_VA_00127	Solar	20 MW	Peak Creek/138-34.5 kV, 30 MVA	Draper 34.5 kV	4/2/2018		Withdrawn	
APCo_VA_00128	Solar	5 MW	Peak Creek/138-12.47 kV, 20 MVA	Memorial Dr 12 kV	4/2/2018		Withdrawn	
APCo_VA_00129	Solar	4.875 MW	Amherst/69-12.47 kV, 25MVA	Rutledge 12.47 kV	12/19/2018, 10:30 AM		Active	3/22/2022
APCo_VA_00130	Solar	11 MW	Sheffield/138-34.5 kV, 30 MVA	Sheffield 34.5 kV	12/27/2018, 10:30 AM		Withdrawn	
APCo_VA_00131	Solar	20MW	Wythe/138-34.5 kV, 35 MVA	Nye Rd 34.5 kV	4/17/2019	A	In Service	9/24/2020
APCo_VA_00132	Nat Gas	2MW	TBD	TBD	9/30/2019	A	In Service	
APCo_VA_00133	Solar	5MW	Fieldale/34-12 kV, 10.9 MVA	Firestone 12 kV	10/25/2019 13:43	A	Active	9/15/2023
APCo_VA_00134	Solar	14MW	Martinsville/138-34.5 kV, 30 MVA	Figsboro 34.5 kV	10/25/2019 1:43:00PM		Withdrawn	
APCo_VA_00135	Solar	10 MW	Wheatland/69-12.47 kV, 20 MVA	Springwood 12.47 kV	1/30/2020 10:41		Withdrawn	
APCo_VA_00136	Hydro	1.44 MW	Haysi/ 69-12.47 kV, 20 MVA	Bartlick 12.47 kV	5/4/2020 11:45		Withdrawn	
APCo_VA_00137	Solar	5 MW	Sheffield/138-34.5 kV, 30 MVA	Cloverleaf 34.5 kV	5/7/2020 10:30AM	A	Active	
APCo_VA_00138	Solar	12 MW	Buckhorn/138-34.5 kV, 30MVA	East Tazewell 34.5 kV	7/9/2020 9:48AM		Withdrawn	
APCo_VA_00139	Solar	3 MW	Sheffield/138-34.5 kV, 30 MVA	Cloverleaf 34.5 kV	9/25/2020 16:09	A	Active	

APCo_VA_00140	Solar	13 MW	Wythe /138-34.5 kV, 25 MVA	Fort Chiswell 34.5 kV	10/15/2020 11:48	A	Active	
APCo_VA_00141	Solar	20 MW	Westlake / 138-34.5 kV, 30 MVA	Westlake 34.5 kV	11/6/2020 17:53		Withdrawn	
APCo_VA_00142	Diesel	0.5 MW	Mcconville 138-12.47 kV, 25 MVA	Rosedale 12.47 kV	12/21/20 3:41PM		In-Service	
APCo_VA_00143	Diesel	3 MW	Mcconville 138-12.47 kV, 25 MVA	Rosedale 12.47 kV	12/21/20 3:41PM		In-Service	4/28/2022
APCo_VA_00144	Solar	5 MW	Oak Level 138-12.47 kV, 20 MVA	Fork Mountain 12.47 kV	01/25/2021 10:30AM	B	Active	
APCo_VA_00145	Solar	5 MW	Oak Level 138-12.47 kV, 20 MVA	Fork Mountain 12.47 kV	01/25/2021 10:30AM	A	Active	
APCo_VA_00146	Solar	18.9 MW	New London 138-34.5 kV, 30 MVA	New London 34.5 kV	1/28/2021 8:04PM	A	Active	
APCo_VA_00147	Solar	20 MW	West Carroll 138-34.5 kV, 30 MVA	Glendale Rd 34.5 kV	2/18/2021 3:50PM	A	Active	7/19/2023
APCo_VA_00148	Solar	20 MW	Sheffield 138-34.5 kV, 30 MVA	Sheffield Terrace 34.5 kV	2/18/2021 5:09PM	B	Active	7/19/2023
APCo_VA_00149	Solar	6.7 MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	2/18/2021 5:10PM		Withdrawn	
APCo_VA_00150	Solar	18.8 MW	Ridgeway 138-34.5 kV, 25 MVA	Lithia Spring 34.5 kV	2/18/2021 5:11PM	A	Active	7/19/2023
APCo_VA_00151	Solar	7.25 MW	Sheffield 138-34.5 kV, 30 MVA	Fisher Farm 34.5 kV	2/18/2021 5:12PM	C	Hold (Interdependency)	
APCo_VA_00152	Battery	10 MW	Saltville 138-12kV, 10.5 MVA	US Gypsum	2/23/2021 10:00		Withdrawn	
APCo_VA_00153	Battery	10 MW	Perkins Park 69-12.47 kV, 20 MVA	Mosby Avenue 12.47 kV	2/23/2021 4:05PM	A	Active	
APCo_VA_00154	Battery	10 MW	Reusens 69-12.47 kV, 20 MVA	Trents Ferry 12.47 kV	2/23/2021 4:05PM	A	Active	
APCo_VA_00155	Solar	16.5 MW	Buckhorn 138-34.5 kV, 30MVA	Gratton 34.5 kV	3/16/2021 9:57AM		Withdrawn	
APCo_VA_00156	Solar	10.0 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	4/16/2021 7:02:00AM	A	Active	
APCo_VA_00157	Solar	7.0 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	4/16/2021 7:02AM		Withdrawn	
APCo_VA_00158	Solar	10.0 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	4/16/2021 7:03AM		Withdrawn	
APCo_VA_00159	Solar	4 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	4/16/2021 7:03AM		Withdrawn	
APCo_VA_00160	Solar	4.5 MW	Amherst 69-12.47 kV, 25MVA	Rutledge 12.47 kV	4/26/2021 12:04PM		Withdrawn	
APCo_VA_00161	Solar	3.5 MW	Ivy Hill 138-12.47 kV, 20 MVA	Perrowville 12.47 kV	4/27/2021 7:52AM	A	Active	
APCo_VA_00162	Solar	5 MW	Ridgeway 138-34.5 kV, 25 MVA	Mason Heights 12.47 kV	4/27/2021 8:23AM	A	Active	
APCo_VA_00163	Solar	5 MW	Collinsville 138-12.47 kV, 22.4 MVA	Kings Mountain 12.47 kV	4/27/2102 8:40PM	A	Active	
APCo_VA_00164	Solar	4.95 MW	Blaine 138-34.5 kV, 30 MVA	Wirtz 34.5 kV	5/4/2021 11:22AM		Withdrawn	
APCo_VA_00165	Solar	5 MW	Buckhorn 138-34.5 kV, 30MVA	East Tazewell 34.5 kV	6/15/2021 9:58AM	B	Active	
APCo_VA_00166	Solar	20.0 MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	6/18/2021 10:00AM	A	Active	
APCo_VA_00167	Solar	16.8 MW	Penhook 138 - 34.5 kV, 30 MVA	Penhook 34.5 kV	6/21/21 12:03PM		Withdrawn	
APCo_VA_00168	Solar	12.6 MW	Penhook 138 - 34.5 kV, 30 MVA	Waters Edge 34.5 kV	6/21/21 12:03PM		Withdrawn	
APCo_VA_00169	Battery	10.0 MW	Perkins Park 69-12.47 kV, 20 MVA	Fairview Heights 12.47 kV	6/21/21 12:13PM	B	Active	
APCo_VA_00170	Battery	10.0 MW	Reusens 69-12.47 kV, 20 MVA	VES 12.47 kV	6/21/21 12:13PM	B	Active	
APCo_VA_00171	Solar	10 MW	Willis Gap 138-34.5 kV, 20 MVA	Cana 34.5 kV	7/12/21 4:52PM		Withdrawn	
APCo_VA_00172	Solar	9 MW	Westlake 138-34.5 kV, 30 MVA	Bluewater 34.5 kV	7/13/21 9:21AM	A	Active	
APCo_VA_00173	Solar	4.9 MW	Sherwill 69-12.47 kV, 20 MVA	Village Highway 12.47 kV	7/14/21 1:107PM		Withdrawn	
APCo_VA_00174	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Rangeley 34.5 kV	7/9/21 3:21PM	A	Active	
APCo_VA_00175	Solar	5 MW	Kumis 138-12.47 kV, 22.4 MVA	Elliston 12.47 kV	7/9/21 4:16PM	A	Active	
APCo_VA_00176	Solar	12 MW	Stuart 69-34.5 kV, 30 MVA	Critz 34.5 kV	7/21/21 2:12PM	A	Active	
APCo_VA_00177	Solar	20 MW	Stuart 69-34.5 kV, 30 MVA	Critz 34.5 kV	7/21/21 2:23PM	B	Withdrawn	
APCo_VA_00178	Solar	4 MW	Sheffield 138-34.5 kV, 30 MVA	Sheffield Terrace 34.5 kV	8/17/21 11:51AM	D	Interdependent	
APCo_VA_00179	Solar	8 MW	Collinsville 138-12.47 kV, 22.4 MVA	Villa Heights 12.47 kV	9/3/2021 4:19PM		Withdrawn	
APCo_VA_00180	Solar	18.2 MW	Progress Park 138-34.5 kV, 30 MVA	Mabetown 34.5 kV	9/17/2021 3:04PM	A	Active	
APCo_VA_00181	Solar	10 MW	James River	Arrington 12.47 kV	10/5/2021 4:03PM	A	Active	
APCo_VA_00182	Solar	20 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	10/12/21 3:16PM	B	Active	
APCo_VA_00183	Solar	15 MW	Austinville 138-12.47 kV, 30 MVA	Poplar Camp 12.47 kV	10/13/21 1:05PM	A	Active	

APCo_VA_00184	Solar	11.45 MW	Wurno 138-34.5 kV, 30 MVA	Snowville 34.5 kV	10/13/21 4:00PM	A	Active	
APCo_VA_00185	Solar	20 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	10/15/2021 10:11AM		Withdrawn	
APCo_VA_00186	Solar	5 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	10/15/2021 10:11AM	B	Active	
APCo_VA_00187	Solar	10 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	10/15/2021 10:11AM		Withdrawn	
APCo_VA_00188	Solar	12 MW	Franklin/138-34.5 kV, 30 MVA	Ferrum 34.5 kV	11/3/21 3:43PM	A	Active	
APCo_VA_00189	Solar	8.25 MW	Stockton/ 138-34.5 kV, 30 MVA	Irisburg 34.5 kV	11/22/21 9:41AM		Withdrawn	
APCo_VA_00190	Solar	10 MW	Martinsville/138-34.5 kV, 30 MVA	Dyers 34.5 kV	11/30/21 11:15AM		Withdrawn	
APCo_VA_00191	Solar	10 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	2/23/2022 2:19PM		Withdrawn	
APCo_VA_00192	Solar	17 MW	Peak Creek/138-34.5 kV, 30 MVA	Draper 34.5 kV	3/7/22 10:48AM	A	Active	
APCo_VA_00193	Solar	20 MW	Tazewell/138-34.5 kV, 30 MVA	Tompson Valley 34.5 kV	3/7/22 10:50AM	A	Active	
APCo_VA_00194	Solar	10 MW	Buckhorn/138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	3/7/22 10:51AM	B	Active	
APCo_VA_00195	Solar	5 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	3/28/22 2:54PM	A	Active	
APCo_VA_00195a	Solar+BESS	10MW	Martinsville/138-34.5 kV, 30 MVA	Dyers 34.5 kV	5/3/2022 3:14PM	A	Active	
APCo_VA_00196	Solar	13.2 MW	Woolwine/69-34.5 kV, 25 MVA	Buffalo Ridge 34.5 kV	5/13/2022 1:07PM	A	Active	
APCo_VA_00197	Solar	10 MW	Blaine 138-34.5 kV, 30 MVA	Wirtz 34.5 kV	5/13/22 12:56PM	A	Active	
APCo_VA_00198	Battery	5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	6/24/22 4:23PM		Withdrawn	
APCo_VA_00199	Solar	3 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	6/28/2022 12:51PM		Withdrawn	
APCo_VA_00200	Solar	4.9 MW	Stockton/ 138-34.5 kV, 30 MVA	Sandy River 34.5 kV	8/13/2022 10:16AM	A	Active	
APCo_VA_00201	Solar	10 MW	Saltville 138-12kV, 10.5 MVA	North Holston 34.5 kV	8/17/2022 4:50PM	A	Active	
APCo_VA_00202	Solar	12 MW	Penhook 138 - 34.5 kV, 30 MVA	Penhook 34.5 kV	10/20/2022 7:43AM	A	Active	
APCo_VA_00203	Solar	5 MW	Wurno 138-34.5 kV, 30 MVA	Route 11 North 34.5 kV	11/18/22 11:02AM	B	Active	
APCo_VA_00204	Solar	5 MW	Wurno 138-34.5 kV, 30 MVA	Dublin 34.5 kV	11/22/2022 1:45PM	A	Active	
APCo_VA_00205	Solar	5 MW	Boxwood 138-12.47 kV, 20 MVA	Winton 12.47 kV	12/2/2022 10:29AM	A	Active	
APCo_VA_00206	Solar	5 MW	Abert 69-12.47 kV, 22.4 MVA	Naola 12.47 kV	12/2/2022 10:39AM	A	Active	
APCo_VA_00207	Solar	2 MW	Mount Union 69-12.47 kV, 20 MVA	Etzler Road 12.47 kV	12/2/2022 10:51AM		Withdrawn	
APCo_VA_00208	Solar	2.5 MW	Gomingo 138-12.47 kV, 20 MVA	Amelon 12.47 kV	12/2/2022 11:16AM		Withdrawn	
APCo_VA_00209	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	12/9/2022 2:25PM	A	Active	
APCo_VA_00210	Solar	4.99 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00211	Solar	4.99 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00212	Solar	3 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00213	Solar	5 MW	James River	Arrington 12.47 kV	2/16/2023 2:17PM	B	Active	
APCo_VA_00214	Solar	4.95 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:44PM		Withdrawn	
APCo_VA_00215	Solar	4.95 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:51PM		Withdrawn	
APCo_VA_00216	Solar	3 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:56PM		Withdrawn	
APCo_VA_00217	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00218	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00219	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00220	Solar	3 MW	Bent Mountain 138-12.47 kV, 10.5 MVA	Copper Hill 34.5 kV	2/28/2023 1:49PM	A	Active	
APCo_VA_00221	Solar	3 MW	Bent Mountain 138-12.47 kV, 10.5 MVA	Copper Hill 34.5 kV	2/28/2023 1:49PM	B	Active	
APCo_VA_00222	Solar	5 MW	Collinsville 138-12.47 kV, 22.4 MVA	Villa Heights 12.47 kV	3/2/2023 4:400PM		Withdrawn	
APCo_VA_00223	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	3/2/2023 5:20PM	B	Active	
APCo_VA_00224	Solar	4.95 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 5:53PM	A	In Review	
APCo_VA_00225	Solar	4.95 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 5:57PM	B	In Review	
APCo_VA_00226	Solar	3 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 6:00PM	C	Interdependent	

APCo_VA_00227	Solar	25 MW	Elk Garden 138-34.5 kV, 30 MVA	Rosedale 12.47 kV	4/26/2023 3:47PM		Withdrawn	
APCo_VA_00228	Solar	12 MW	Claypool Hill 138-12.47 kV, 25 MVA	Wardell 12.47 kV	5/25/2023 10:45AM		Withdrawn	
APCo_VA_00229	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:12AM	A	Active	
APCo_VA_00230	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:16AM	B	Active	
APCo_VA_00231	Solar	3 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:21AM	C	Interdependent	
APCo_VA_00232	Solar	7.5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	6/22/2023 2:47PM	B	Active	
APCo_VA_00233	Solar	5 MW	Independence 69-34.5 kV, 20 MVA	Rural 34.5 kV	7/25/2023 11:36AM	A	Active	
APCo_VA_00234	Solar	5 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	B	Active	
APCo_VA_00235	Solar	5 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	C	Interdependent	
APCo_VA_00236	Solar	3 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	D	Interdependent	
APCo_VA_00237	Solar	4 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	A	Active	
APCo_VA_00238	Solar	4 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	B	Active	
APCo_VA_00239	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	C	Interdependent	
APCo_VA_00240	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	D	Interdependent	
APCo_VA_00241	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	E	Interdependent	
APCo_VA_00242	Solar	1 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	F	Interdependent	
APCo_VA_00243	Solar	2 MW	Bent Mountain 138-124.47 kV, 7.5 MVA	Copper Hill 34.5 kV	8/31/2023 8:35AM	C	Interdependent	
APCo_VA_00244	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	8/31/2023 9:16AM	D	Interdependent	
APCo_VA_00245	Solar	3 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47	8/31/2023 9:16AM	E	Interdependent	
APCo_VA_00246	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	A	Active	
APCo_VA_00247	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	B	Active	
APCo_VA_00248	Solar	2 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	C	Interdependent	
APCo_VA_00249	Solar+BESS	10.0 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/14/2023 10:51AM	C	Interdependent	
APCo_VA_00250	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 11:51AM	D	Interdependent	
APCo_VA_00251	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 4:22PM	E	Interdependent	
APCo_VA_00252	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 4:38PM	F	Interdependent	
APCo_VA_00253	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/2023 5:39PM	D	Interdependent	
APCo_VA_00254	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/2023 6:04PM	E	Interdependent	
APCo_VA_00255	Solar	2 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/23 6:24PM	F	Interdependent	
APCo_VA_00256	Solar	2.5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	10/16/2023 3:22PM	G	Interdependent	
APCo_VA_00257	Solar	5 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	10/18/2023 10:20AM	B	Active	
APCo_VA_00258	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/19/2023 4:25PM	A	Active	
APCo_VA_00259	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/20/2023 2:39PM	B	Active	
APCo_VA_00260	Solar	4.375 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	10/22/2023 10:13AM		Withdrawn	
APCo_VA_00261	Solar	4.375 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	10/22/2023 10:16AM		Withdrawn	
APCo_VA_00262	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 1:40PM	C	Interdependent	
APCo_VA_00263	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 2:22PM	D	Interdependent	
APCo_VA_00264	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 2:28PM	E	Interdependent	
APCo_VA_00265	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	11/1/2023 5:09PM	F	Interdependent	
APCo_VA_00266	BESS	10 MW	East Danville, 69-12.47 kV, 8.4 MVA	Lorillard 12.47 kV	11/16/2023 11:33AM	A	Active	
APCo_VA_00267	BESS	20 MW	East Danville, 69-12.47 kV, 8.4 MVA	Lorillard 12.47 kV	11/16/2023 11:33AM	B	Active	
APCo_VA_00268	Solar	5 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/04/2023 6:24PM	A	Active	
APCo_VA_00269	Solar	5 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/05/2023 10:34AM	B	Active	
APCo_VA_00270	Solar	3 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/05/2023 5:00PM	C	Interdependent	

APCo_VA_00271	Solar	3 MW	Hans Meadow 69-12.47 kV, 25 MVA	Market Place 12.47 kV	1/24/2024 11:38AM	A	Active	
APCo_VA_00272	Solar	5 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV	1/26/2024 3:00PM	A	Active	
APCo_VA_00273	Solar	5 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV	1/26/2024 3:09PM	B	Active	
APCo_VA_00274	Solar	3 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV	1/26/2024 3:09PM	C	Active	
APCo_VA_00275	Solar	4 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	3/20/2024 9:36AM	B	Active	
APCo_VA_00276	Solar	3 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	3/20/2024 9:39AM	C	Interdependent	
APCo_VA_00277	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:33AM	A	Active	
APCo_VA_00278	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Duffield 12.47	3/24/2024 9:37AM	B	Active	
APCo_VA_00279	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:37AM	C	Interdependent	
APCo_VA_00280	Solar	14.5 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:49AM	D	Interdependent	
APCo_VA_00281	BESS	5.988 MW	Glade 69-34.5 kV, 30 MVA	Whitetop	3/27/2024 10:40AM	A	Active	
APCo_VA_00282	BESS	2.994 MW	Glade 69-34.5 kV, 30 MVA	Whitetop	3/27/2024 10:40AM	B	Active	
APCo_VA_00283	Solar	5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	3/28/2024 8:48AM	H	Interdependent	
APCo_VA_00284	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:50AM	A	Active	
APCo_VA_00285	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	3/28/2024 8:52AM	B	Active	
APCo_VA_00286	Solar	4.4 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:52AM	C	Interdependent	
APCo_VA_00287	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:52AM	D	Interdependent	
APCo_VA_00288	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	3/28/2024 8:52AM	E	Interdependent	
APCo_VA_00289	Solar	2.5 MW	Gomingo 138-12.47 kV, 20 MVA	Amelon 12.47 kV	3/29/2024 9:15AM	A	Active	
APCo_VA_00290	Solar	2 MW	Mount Union 69-12.47 kV, 20 MVA	Etzler Road 12.47 kV	3/29/2024 9:15AM	A	Active	
APCo_VA_00291	Solar	5 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.5 kV	4/10/24 9:40AM		Withdrawn	
APCo_VA_00292	Solar	5 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.5 kV	4/10/24 9:40AM		Withdrawn	
APCo_VA_00293	Solar	3 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.3 kV	4/10/24 9:41AM		Withdrawn	
APCo_VA_00294	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/10/24 9:41AM	A	Active	
APCo_VA_00295	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	B	Active	
APCo_VA_00296	Solar	3 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	C	Interdependent	
APCo_VA_00297	Solar	3 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	D	Interdependent	
APCo_VA_00298	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	E	Interdependent	
APCo_VA_00299	Solar	3 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/2024 9:48AM	F	Interdependent	
APCo_VA_00300	Solar	9 MW	Independence 69-34.5 kV, 20 MVA	Rural 34.5 kV	4/24/2024 8:48AM	B	Active	
APCo_VA_00301	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	5/9/2024 9:19AM	C	Interdependent	
APCo_VA_00302	Solar	2 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	6/24/2024 9:39AM	D	Interdependent	

Xfmr MVA is max nameplate rating, although distribution station transformer loading shall be limited to 90% of their normal seasonal capability rating.

Withdrawn
Active
In Service