

As of 01/01/2025

APCo Dist Queue #	SGF Physical Address	Fuel Type	Capacity (MW)	Substation/Transformer	Circuit	Date of Submission of Final Completed Interconnect Request	Interdependency Status	Project Status	Date of Final Executed SGIA
Pre-Queue	Flanagan Dam Rd, Haysi, VA	Water	1.2 MW	Haysi/ 69-12.47 kV, 20 MVA	Bartlick 12.47 kV	7/7/2014		Withdrawn	
APCo_VA_00100	2355 Salem Rd, Schuyler, VA	Water	.622 MW	Schuyler/46-12.47 kV, 2 MVA	Schuyler 12.47 kV	9/3/2014	A	Active	6/11/2015
APCo_VA_00101	Depot Rd, Rustburg, VA	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	8/13/2015		In Service	9/16/2020
APCo_VA_00102	6 Mile Post Rd, Rocky Mount, VA	Solar	10 MW	Franklin/138-12.47 kV, 22.4 MVA	Grassy Hill 12.47 kV	12/3/2015, 11:06 AM		Withdrawn	
APCo_VA_00103	3311 Mud Pike, Christiansburg, VA	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	12/3/2015, 2:46 PM		Withdrawn	
APCo_VA_00104	2684 Mide Pike, Christiansburg, VA	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Plum Creek 12.47 kV	12/4/2015, 11:59 AM		Withdrawn	
APCo_VA_00105a	2900 Lamb Cir, Christiansburg, VA	Solar	1 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	5/17/2016		In Service	12/5/2016
APCo_VA_00105b	6 Mile Post Rd, Rocky Mount, VA	Solar	10 MW	Franklin/138-12.47 kV, 22.4 MVA	Grassy Hill 12.47 kV	2/6/2017, 11:57 AM		Withdrawn	
APCo_VA_00106	2684 Mud Pike Rd, Christiansburg, VA	Solar	10 MW	Edgemont/138-12.47 kV, 22.4 MVA	Mudpike 12.47 kV	2/8/2017, 1:00 PM		Withdrawn	
APCo_VA_00107	Depot Rd, Rustburg, VA	Solar	10 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/22/2017, 10:52 AM		In Service	9/16/2020
APCo_VA_00108	Monte Vista Dr, Pulaski, VA	Solar	18.4 MW	Peak Creek/138-34.5 kV, 30 MVA or	Not determined	2/24/2017, 9:51 AM		Withdrawn	
APCo_VA_00109	694 Gap of Ridge Rd, Rural Retreat, VA	Solar	20 MW	Rural Retreat/138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 9:52 AM		Withdrawn	
APCo_VA_00110	140 Foggy Ridge Rd, Rocky Mount, VA	Solar	10 MW	Blaine/138-34.5 kV, 30 MVA	Wirtz 34.5 kV	2/24/2017, 12:18 PM		Withdrawn	
APCo_VA_00111	Kents Ln, Wytheville, VA	Solar	15 MW	Progress Park/138-34.5 kV, 30MVA	Progress Park or Mabetown	2/24/2017, 12:18 PM		Withdrawn	
APCo_VA_00112	4834 Old Franklin Tpk, Glade Hill, VA	Solar	10 MW	Redwood /138-12.47 kV, 20 MVA	Truevine 12.47 kV	2/24/2017, 12:20 PM		Withdrawn	
APCo_VA_00113	580 Kin Vale Rd, Rocky Mount, VA	Solar	10 MW	Blaine/138-34.5 kV, 30 MVA	Burnt Chimney 34.5 kV	2/24/2017, 12:20 PM		Withdrawn	
APCo_VA_00114	678 Brookneal Hwy, Rustburg, VA	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/24/2017, 12:22 PM		Withdrawn	
APCo_VA_00115	1146 Campbell Hwy, Rustburg, VA	Solar	10 MW	Rustburg/138-12.47 kV, 20 MVA	Rustburg 12.47 kV	2/24/2017, 12:22 PM		Withdrawn	
APCo_VA_00116	Gose Mill Rd, Tazewell, VA	Solar	5 MW	Buckhorn/138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	2/24/2017, 2:17 PM		Withdrawn	
APCo_VA_00117	Narrows, VA	Solar	5 MW	Not determined	Not determined	2/24/2017, 2:17 PM		Withdrawn	
APCo_VA_00118	Ringgold Rd, Ringgold, VA	Solar	10 MW	Not in APCo service territory	Not in APCo service territory	2/24/20017, 3:28 PM		Withdrawn	
APCo_VA_00119	Cline & Citizens Rd, Rural Retreat, VA	Solar	5 MW	Rural Retreat /138-34.5 kV/25 MVA	Groseclose 34.5 kV	2/24/2017, 3:49 PM		Withdrawn	
APCo_VA_00120	630 Main St., Rural Retreat, VA	Solar	5 MW	Rural Retreat/138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00121	1178 Lovers Ln, Wytheville, VA	Solar	10 MW	Wythe/138-34.5 kV, 25 or 35 MVA	Not determined	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00122	340 Citizen Rd, Rural Retreat, VA	Solar	6 MW	Rural Retreat / 138-34.5 kV, 25 MVA	Rural Retreat 34.5 kV	2/24/2017, 4 PM		Withdrawn	
APCo_VA_00123	Mud Pike Rd, Christiansburg, VA	Solar	20 MW	Edgemont/138-12.47 kV, 22.4 MVA	Not determined	2/24/2017, 6:11 PM		Withdrawn	
APCo_VA_00124	1970 Roanoke Blvd, Salem, VA	Nat. Gas	1.43 MW	V.A. Hospital/34.5-4 kV, 10 MVA	34.5 kV Sub transmission loc	4/17/2017	A	Active	
APCo_VA_00125	Jones Ridge & Mountain Valley Rds, Henry	Solar	20 MW	Stockton/ 138-34.5 kV, 30 MVA	Sandy River 34.5 kV	11/16/2016		In-Service	9/23/2020
APCo_VA_00126	2128 Lynbrook Rd, Lynchburg, VA	Solar	15 MW	Lynbrook/138-12 kV, 20 MVA	Will require 2 POIs, undeter	Request from PJM to study		Withdrawn	
APCo_VA_00127	1945 Warden Spring Rd, Pulaski, VA	Solar	20 MW	Peak Creek/138-34.5 kV, 30 MVA	Draper 34.5 kV	4/2/2018		Withdrawn	
APCo_VA_00128	1945 Warden Spring Rd, Pulaski, VA	Solar	5 MW	Peak Creek/138-12.47 kV, 20 MVA	Memorial Dr 12 kV	4/2/2018		Withdrawn	
APCo_VA_00129	SR 732 & Richmond Hwy, Amherst, VA	Solar	4.875 MW	Amherst/69-12.47 kV, 25MVA	Rutledge 12.47 kV	12/19/2018, 10:30 AM		Active	3/22/2022
APCo_VA_00130	1020 Fisher Farm Rd, Martinsville, VA	Solar	11 MW	Sheffield/138-34.5 kV, 30 MVA	Sheffield 34.5 kV	12/27/2018, 10:30 AM		Withdrawn	
APCo_VA_00131	Nye Rd, Wytheville, VA	Solar	20MW	Wythe/138-34.5 kV, 35 MVA	Nye Rd 34.5 kV	4/17/2019		In Service	9/24/2020
APCo_VA_00132	Corporate Cir, Salem, VA	Nat Gas	2MW	Glenmary/138-12.47 kV, 25 MVA	TOC 12.47 kV	9/30/2019		In Service	
APCo_VA_00133	1541-1411 Co Rd 606 Bassett, VA 24055	Solar	5MW	Fieldale/34-12 kV, 20 MVA	Firestone 12 kV	10/25/2019 13:43		Active	9/15/2023
APCo_VA_00134	2-398 Beaver Hills Club Rd, Collinsville, VA	Solar	14MW	Martinsville/138-34.5 kV, 30 MVA	Figsboro 34.5 kV	10/25/2019 1:43:00PM		Withdrawn	
APCo_VA_00135	Wheatland Rd, Fincastle, VA	Solar	10 MW	Wheatland/69-12.47 kV, 20 MVA	Springwood 12.47 kV	1/30/2020 10:41		Withdrawn	
APCo_VA_00136	Flannagan Dam Rd, Haysi, VA	Hydro	1.44 MW	Haysi/ 69-12.47 kV, 20 MVA	Bartlick 12.47 kV	5/4/2020 11:45		Withdrawn	
APCo_VA_00137	310-398 Ebony Dr, Martinsville, VA	Solar	5 MW	Sheffield/138-34.5 kV, 30 MVA	Cloverleaf 34.5 kV	5/7/2020 10:30AM	A	Active	
APCo_VA_00138	543-537 E Riverside Dr, N Tazewell, VA	Solar	12 MW	Buckhorn/138-34.5 kV, 30MVA	East Tazewell 34.5 kV	7/9/2020 9:48AM		Withdrawn	
APCo_VA_00139	310-398 Ebony Dr, Martinsville, VA	Solar	3 MW	Sheffield/138-34.5 kV, 30 MVA	Cloverleaf 34.5 kV	9/25/2020 16:09	A	Active	
APCo_VA_00140	E Lee Hwy, Wytheville, VA	Solar	13 MW	Wythe /138-34.5 kV, 25 MVA	Fort Chiswell 34.5 kV	10/15/2020 11:48	A	Active	
APCo_VA_00141	14186 Booker T Washington Hwy, Moneta,	Solar	20 MW	Westlake / 138-34.5 kV, 30 MVA	Westlake 34.5 kV	11/6/2020 17:53		Withdrawn	
APCo_VA_00142	1501 Graves Mill Rd, Lynchburg, VA	Diesel	0.5 MW	Mcconville 138-12.47 kV, 25 MVA	Rosedale 12.47 kV	12/21/20 3:41PM		In-Service	
APCo_VA_00143	1501 Graves Mill Rd, Lynchburg, VA	Diesel	3 MW	Mcconville 138-12.47 kV, 25 MVA	Rosedale 12.47 kV	12/21/20 3:41PM		In-Service	4/28/2022
APCo_VA_00144	1778 Virgil Goode Hwy, Oak Level, VA	Solar	5 MW	Oak Level 138-12.47 kV, 20 MVA	Fork Mountain 12.47 kV	01/25/2021 10:30AM	B	Active	
APCo_VA_00145	11918 Henry Rd, Henry, VA	Solar	5 MW	Oak Level 138-12.47 kV, 20 MVA	Fork Mountain 12.47 kV	01/25/2021 10:30AM	A	Active	
APCo_VA_00146	4325 Thomas Jefferson Rd, Forest, VA	Solar	18.9 MW	New London 138-34.5 kV, 30 MVA	New London 34.5 kV	1/28/2021 8:04PM	A	Active	
APCo_VA_00147	Hebron Rd, Galax, VA	Solar	20 MW	West Carroll 138-34.5 kV, 30 MVA	Glendale Rd 34.5 kV	2/18/2021 3:50PM	A	Active	7/19/2023
APCo_VA_00148	Joseph Martin Hwy, Martinsville, VA	Solar	20 MW	Sheffield 138-34.5 kV, 30 MVA	Sheffield Terrace 34.5 kV	2/18/2021 5:09PM	B	Active	7/19/2023
APCo_VA_00149	Burnt Chimney Rd, Wirtz, VA	Solar	6.7 MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	2/18/2021 5:10PM		Withdrawn	
APCo_VA_00150	Marborne Manor Rd, Ridgeway, VA	Solar	18.8 MW	Ridgeway 138-34.5 kV, 25 MVA	Lithia Spring 34.5 kV	2/18/2021 5:11PM	A	Active	7/19/2023
APCo_VA_00151	Fisher Farm Rd, Martinsville, VA	Solar	7.25 MW	Sheffield 138-34.5 kV, 30 MVA	Fisher Farm 34.5 kV	2/18/2021 5:12PM	C	Interdependent	

APCo_VA_00152	Government Plant Rd	Battery	10 MW	Saltville 138-12kV, 10.5 MVA	US Gypsum	2/23/2021 10:00		Withdrawn	
APCo_VA_00153	2904 Caroll Avenue, Lynchburg, VA	Battery	10 MW	Perkins Park 69-12.47 kV, 20 MVA	Mosby Avenue 12.47 kV	2/23/2021 4:05PM		Withdrawn	
APCo_VA_00154	109 Old Trent's Ferry Rd & 3920 Harbor St.	Battery	10 MW	Reusens 69-12.47 kV, 20 MVA	Trents Ferry 12.47 kV	2/23/2021 4:05PM	A	Active	
APCo_VA_00155	Gratton Rd, Tazewell, VA 24651	Solar	16.5 MW	Buckhorn 138-34.5 kV, 30MVA	Gratton 34.5 kV	3/16/2021 9:57AM		Withdrawn	
APCo_VA_00156	Orby Cantrell Hwy, Pound, VA 24279	Solar	10.0 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	4/16/2021 7:02:00AM	A	Active	
APCo_VA_00157	Bold Camp Rd, Pound, VA 24279	Solar	7.0 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	4/16/2021 7:02AM		Withdrawn	
APCo_VA_00158	Bold Camp Rd, Pound, VA 24279	Solar	10.0 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	4/16/2021 7:03AM		Withdrawn	
APCo_VA_00159	Bold Camp Rd, Pound, VA 24279	Solar	4 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	4/16/2021 7:03AM		Withdrawn	
APCo_VA_00160	Richmond Hwy, Amherst, VA 24521	Solar	4.5 MW	Amherst 69-12.47 kV, 25MVA	Rutledge 12.47 kV	4/26/2021 12:04PM		Withdrawn	
APCo_VA_00161	White Rd, Good, VA 24556	Solar	3.5 MW	Ivy Hill 138-12.47 kV, 20 MVA	Perrowville 12.47 kV	4/27/2021 7:52AM	A	Active	
APCo_VA_00162	9860 Greensboror Rd, Ridgeway, VA 24148	Solar	5 MW	Ridgeway 138-34.5 kV, 25 MVA	Mason Heights 12.47 kV	4/27/2021 8:23AM	A	Active	
APCo_VA_00163	77 Thomas Rd, Collinsville, VA 24078	Solar	5 MW	Collinsville 138-12.47 kV, 22.4 MVA	Kings Mountain 12.47 kV	4/27/2102 8:40PM	A	Active	
APCo_VA_00164	Digby Green Rd, Boones Mill, VA	Solar	4.95 MW	Blaine 138-34.5 kV, 30 MVA	Wirtz 34.5 kV	5/4/2021 11:22AM		Withdrawn	
APCo_VA_00165	543-537 E Riverside Dr, N Tazewell, VA	Solar	5 MW	Buckhorn 138-34.5 kV, 30MVA	East Tazewell 34.5 kV	6/15/2021 9:58AM	B	Active	
APCo_VA_00166	Burnt Chimney Rd, Wirtz, VA	Solar	20.0 MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	6/18/2021 10:00AM	A	Active	
APCo_VA_00167	15550 Old Franklin Turnpike, Penhook, VA	Solar	16.8 MW	Penhook 138 - 34.5 kV, 30 MVA	Penhook 34.5 kV	6/21/21 12:03PM		Withdrawn	
APCo_VA_00168	15550 Old Franklin Turnpike, Penhook, VA	Solar	12.6 MW	Penhook 138 - 34.5 kV, 30 MVA	Waters Edge 34.5 kV	6/21/21 12:03PM		Withdrawn	
APCo_VA_00169	2904 Caroll Avenue, Lynchburg, VA	Battery	10.0 MW	Perkins Park 69-12.47 kV, 20 MVA	Fairview Heights 12.47 kV	6/21/21 12:13PM		Withdrawn	
APCo_VA_00170	109 Old Trent's Ferry Rd & 3920 Harbor St.	Battery	10.0 MW	Reusens 69-12.47 kV, 20 MVA	VES 12.47 kV	6/21/21 12:13PM	B	Active	
APCo_VA_00171	Flint Hill Rd, Cana VA, 24317	Solar	10 MW	Willis Gap 138-34.5 kV, 20 MVA	Cana 34.5 kV	7/12/21 4:52PM		Withdrawn	
APCo_VA_00172	Gilford Rd, Moneta, VA 24121	Solar	9 MW	Westlake 138-34.5 kV, 30 MVA	Bluewater 34.5 kV	7/13/21 9:21AM	A	Active	
APCo_VA_00173	Village Highway, Concord, VA 24538	Solar	4.9 MW	Sherwill 69-12.47 kV, 20 MVA	Village Highway 12.47 kV	7/14/21 1:107PM		Withdrawn	
APCo_VA_00174	271 Co. Rd 747, Fieldale, VA 24089	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Rangeley 34.5 kV	7/9/21 3:21PM		Withdrawn	
APCo_VA_00175	Roanoke Rd, Elliston, VA 24087	Solar	5 MW	Kumis 138-12.47 kV, 22.4 MVA	Elliston 12.47 kV	7/9/21 4:16PM		Withdrawn	
APCo_VA_00176	Commerce Dr, Stuart, VA 24171	Solar	12 MW	Stuart 69-34.5 kV, 30 MVA	Critz 34.5 kV	7/21/21 2:12PM		Withdrawn	
APCo_VA_00177	Commerce Dr, Stuart, VA 24171	Solar	20 MW	Stuart 69-34.5 kV, 30 MVA	Critz 34.5 kV	7/21/21 2:23PM		Withdrawn	
APCo_VA_00178	217 New Light Church Rd, Ridgeway, VA	Solar	4 MW	Sheffield 138-34.5 kV, 30 MVA	Sheffield Terrace 34.5 kV	8/17/21 11:51AM	D	Interdependent	
APCo_VA_00179	4173 River Rd, Fieldale, VA 24089	Solar	8 MW	Collinsville 138-12.47 kV, 22.4 MVA	Villa Heights 12.47 kV	9/3/2021 4:19PM		Withdrawn	
APCo_VA_00180	3724 Peppers Ferry Rd, Wytheville, VA	Solar	18.2 MW	Progress Park 138-34.5 kV, 30 MVA	Mabetown 34.5 kV	9/17/2021 3:04PM	A	Active	
APCo_VA_00181	Oak Ridge Rd, Lovingston, VA	Solar	10 MW	James River	Arrington 12.47 kV	10/5/2021 4:03PM	A	Active	
APCo_VA_00182	0 River Rd, Fieldale, VA 24089	Solar	20 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	10/12/21 3:16PM		Withdrawn	
APCo_VA_00183	772 St Rte 608, Austinville, VA	Solar	15 MW	Austinville 138-12.47 kV, 30 MVA	Poplar Camp 12.47 kV	10/13/21 1:05PM	A	Active	
APCo_VA_00184	Lowmans Ferry Rd, Pulaski, VA	Solar	11.45 MW	Wurno 138-34.5 kV, 30 MVA	Snowville 34.5 kV	10/13/21 4:00PM	A	Active	
APCo_VA_00185	Bold Camp Rd, Pound, VA 24279	Solar	20 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	10/15/2021 10:11AM		Withdrawn	
APCo_VA_00186	Bold Camp Rd, Pound, VA 24279	Solar	5 MW	Lick Fork 69-34.5 kV, 10.5 MVA	Birchfield 34.5 kV	10/15/2021 10:11AM	B	Active	
APCo_VA_00187	Bold Camp Rd, Pound, VA 24279	Solar	10 MW	Clintwood 69-12.47 kV, 20 MVA	Coeburn Road 12.47 kV	10/15/2021 10:11AM		Withdrawn	
APCo_VA_00188	Franklin St, Rocky Mount, VA	Solar	12 MW	Franklin/138-34.5 kV, 30 MVA	Ferrug 34.5 kV	11/3/21 3:43PM	A	Active	
APCo_VA_00189	460 Stonewall Jackson Trl, Martinsville, VA	Solar	8.25 MW	Stockton/ 138-34.5 kV, 30 MVA	Irisburg 34.5 kV	11/22/21 9:41AM		Withdrawn	
APCo_VA_00190	Clearview Dr, Martinsville, VA	Solar	10 MW	Martinsville/138-34.5 kV, 30 MVA	Dyers 34.5 kV	11/30/21 11:15AM		Withdrawn	
APCo_VA_00191	Izaak Walton Rd, Madison Heights, VA	Solar	10 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	2/23/2022 2:19PM		Withdrawn	
APCo_VA_00192	Monte Vista Dr, Pulaski, VA	Solar	17 MW	Peak Creek/138-34.5 kV, 30 MVA	Draper 34.5 kV	3/7/22 10:48AM	A	Active	
APCo_VA_00193	Cavitts Creek Rd, N. Tazewell, VA	Solar	20 MW	Tazewell/138-34.5 kV, 30 MVA	Tompson Valley 34.5 kV	3/7/22 10:50AM	A	Active	
APCo_VA_00194	State Rte 645, N. Tazewell, VA	Solar	10 MW	Buckhorn/138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	3/7/22 10:51AM	B	Active	
APCo_VA_00195	723 Twin Springs Rd	Solar	5 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	3/28/22 2:54PM	A	Active	
APCo_VA_00195a	Clearview Dr, Martinsville, VA	Solar+BESS	10MW	Martinsville/138-34.5 kV, 30 MVA	Dyers 34.5 kV	5/3/2022 3:14PM	A	Active	
APCo_VA_00196	Woolwine Hwy, Woolwine, VA	Solar	13.2 MW	Woolwine/69-34.5 kV, 25 MVA	Buffalo Ridge 34.5 kV	5/13/2022 1:07PM	A	Active	
APCo_VA_00197	Foggy Ridge Rd, Rocky Mount, VA	Solar	10 MW	Blaine 138-34.5 kV, 30 MVA	Wirtz 34.5 kV	5/13/22 12:56PM	A	Active	
APCo_VA_00198	Orby Cantrell Hwy, Pound, VA 24279	Battery	5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	6/24/22 4:23PM		Withdrawn	
APCo_VA_00199	723 Twin Springs Rd	Solar	3 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	6/28/2022 12:51PM		Withdrawn	
APCo_VA_00200	Jones Ridge Rd, Axton, VA 24054	Solar	4.9 MW	Stockton/ 138-34.5 kV, 30 MVA	Sandy River 34.5 kV	8/13/2022 10:16AM	A	Active	
APCo_VA_00201	135 Cedar Branch Rd, Saltville, VA	Solar	10 MW	Saltville 138-12kV, 10.5 MVA	North Holston 34.5 kV	8/17/2022 4:50PM	A	Active	
APCo_VA_00202	Jack's Creek Rd, Union Hall, VA 24092	Solar	12 MW	Penhook 138 - 34.5 kV, 30 MVA	Penhook 34.5 kV	10/20/2022 7:43AM	A	Active	
APCo_VA_00203	4900 Ben Curt Ln, Dublin VA, 24084	Solar	5 MW	Wurno 138-34.5 kV, 30 MVA	Route 11 North 34.5 kV	11/18/22 11:02AM	B	Active	
APCo_VA_00204	5209 Rockwood Rd, Dublin VA, 24084	Solar	5 MW	Wurno 138-34.5 kV, 30 MVA	Dublin 34.5 kV	11/22/2022 1:45PM	A	Active	
APCo_VA_00205	237 Airsports Dr, Amherst VA 24521	Solar	5 MW	Boxwood 138-12.47 kV, 20 MVA	Winton 12.47 kV	12/2/2022 10:29AM	A	Active	
APCo_VA_00206	801 Phyllis Lea Dr, Madison Heights, VA	Solar	5 MW	Abert 69-12.47 kV, 22.4 MVA	Naola 12.47 kV	12/2/2022 10:39AM		Withdrawn	
APCo_VA_00207	Catawba Rd, Daleville, VA 24175	Solar	2 MW	Mount Union 69-12.47 kV, 20 MVA	Etzler Road 12.47 kV	12/2/2022 10:51AM		Withdrawn	

APCo_VA_00208	211 Tyree Cir, Madison Heights, VA	Solar	2.5 MW	Gomingo 138-12.47 kV, 20 MVA	Amelon 12.47 kV	12/2/2022 11:16AM		Withdrawn	
APCo_VA_00209	Colonial Hwy, Rustburg, VA 24588	Solar	5 MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	12/9/2022 2:25PM	A	Active	
APCo_VA_00210	2217 Floyd Pike, Hillsville, VA 24343	Solar	4.99 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00211	2217 Floyd Pike, Hillsville, VA 24343	Solar	4.99 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00212	2217 Floyd Pike, Hillsville, VA 24343	Solar	3 MW	Huffman 138-34.5 kV, 30 MVA	Dugspur 34.5 kV	1/24/2023 11:10AM		Withdrawn	
APCo_VA_00213	Oak Ridge Rd, Lovingston, VA	Solar	5 MW	James River	Arrington 12.47 kV	2/16/2023 2:17PM	B	Active	
APCo_VA_00214	5975 Alberene Road, Esmont, VA 22937	Solar	4.95 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:44PM		Withdrawn	
APCo_VA_00215	5976 Alberene Road, Esmont, VA 22937	Solar	4.95 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:51PM		Withdrawn	
APCo_VA_00216	5976 Alberene Road, Esmont, VA 22937	Solar	3 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	2/23/2023 2:56PM		Withdrawn	
APCo_VA_00217	9150 Reed Rd, Bent Mtn, VA 24059	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00218	9151 Reed Rd, Bent Mtn, VA 24059	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00219	9205 Poor Mtn Rd, Bent Mtn, VA 24059	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	2/24/2023 11:00AM		Withdrawn	
APCo_VA_00220	Tinsley Lane, Bent Mtn, VA 24059	Solar	3 MW	Bent Mountain 138-12.47 kV, 10.5 MVA	Copper Hill 34.5 kV	2/28/2023 1:49PM	A	Active	
APCo_VA_00221	Tinsley Lane, Bent Mtn, VA 24059	Solar	3 MW	Bent Mountain 138-12.47 kV, 10.5 MVA	Copper Hill 34.5 kV	2/28/2023 1:49PM	B	Active	
APCo_VA_00222	4173 River Rd, Fieldale, VA 24089	Solar	5 MW	Collinsville 138-12.47 kV, 22.4 MVA	Villa Heights 12.47 kV	3/2/2023 4:400PM		Withdrawn	
APCo_VA_00223	0 River Rd, Fieldale, VA 24089	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	3/2/2023 5:20PM	B	Active	
APCo_VA_00224	Houston Lane, Glen Lyn, VA 24093	Solar	4.95 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 5:53PM	A	In Review	
APCo_VA_00225	Houston Lane, Glen Lyn, VA 24093	Solar	4.95 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 5:57PM	B	In Review	
APCo_VA_00226	Houston Lane, Glen Lyn, VA 24093	Solar	3 MW	Glen Lyn 138-34.5 kV, 30 MVA	Peterstown 34.5 kV	4/3/2023 6:00PM	C	Interdependent	
APCo_VA_00227	Old Hwy 19, Cedar Bluff, VA 24609	Solar	25 MW	Elk Garden 138-34.5 kV, 30 MVA	Rosedale 12.47 kV	4/26/2023 3:47PM		Withdrawn	
APCo_VA_00228	Old Hwy 19, Cedar Bluff, VA 24609	Solar	12 MW	Claypool Hill 138-12.47 kV, 25 MVA	Wardell 12.47 kV	5/25/2023 10:45AM		Withdrawn	
APCo_VA_00229	5975 Alberene Road, Esmont, VA	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:12AM		Withdrawn	
APCo_VA_00230	5976 Alberene Road, Esmont, VA	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:16AM		Withdrawn	
APCo_VA_00231	5976 Alberene Road, Esmont, VA 22937	Solar	2.4 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	6/20/2023 11:21AM	A	Active	
APCo_VA_00232	7382 S Fork Rd, Pound, VA 24279	Solar	7.5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	6/22/2023 2:47PM	B	Active	
APCo_VA_00233	1141 Old Bridle Creek Dr, Independence, VA	Solar	5 MW	Independence 69-34.5 kV, 20 MVA	Rural 34.5 kV	7/25/2023 11:36AM	A	Active	
APCo_VA_00234	719 Ebenezer Rd, Amherst, VA 24521	Solar	5 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	B	Active	
APCo_VA_00235	719 Ebenezer Rd, Amherst, VA 24521	Solar	5 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	C	Interdependent	
APCo_VA_00236	719 Ebenezer Rd, Amherst, VA 24521	Solar	3 MW	Amherst 69-12.47 kV, 25MVA	Ebenezer 12,47 kV	8/30/2023 8:12AM	D	Interdependent	
APCo_VA_00237	9150 Reed Rd, Bent Mtn, VA 24059	Solar	4 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	A	Active	
APCo_VA_00238	9150 Reed Rd, Bent Mtn, VA 24059	Solar	4 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	B	Active	
APCo_VA_00239	9150 Redd Rd, Bent Mtn, VA 24059	Solar	3 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/22/2023 5:57PM	C	Interdependent	
APCo_VA_00240	9205 Poor Mtn Rd, Bent Mtn, VA 24059	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	D	Interdependent	
APCo_VA_00241	9205 Poor Mtn Rd, Bent Mtn, VA 24059	Solar	2 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	E	Interdependent	
APCo_VA_00242	9205 Poor Mtn Rd, Bent Mtn, VA 24059	Solar	1 MW	Bent Mountain 138-12.47 kV, 7.5 MVA	Airpoint 12.47 kV	8/31/2023 7:44AM	F	Interdependent	
APCo_VA_00243	Tinsley Lane, Bent Mtn, VA 24059	Solar	2 MW	Bent Mountain 138-124.47 kV, 7.5 MVA	Copper Hill 34.5 kV	8/31/2023 8:35AM	C	Interdependent	
APCo_VA_00244	5975 Alberene Road, Esmont, VA 22937	Solar	4.5 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	8/31/2023 9:16AM	B	Active	
APCo_VA_00245	5975 Alberene Road, Esmont, VA 22937	Solar	3 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47	8/31/2023 9:16AM	C	Interdependent	
APCo_VA_00246	Old Giles Rd, Dublin, VA 24084	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	A	Active	
APCo_VA_00247	Old Giles Rd, Dublin, VA 24084	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	B	Active	
APCo_VA_00248	Old Giles Rd, Dublin, VA 24084	Solar	2 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	8/31/2023 11:29AM	C	Interdependent	
APCo_VA_00249	Sarvis Rd, Pound, VA 24279	Solar+BESS	10.0 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/14/2023 10:51AM	C	Interdependent	
APCo_VA_00250	7905 S. Fork Rd, Pound VA 24279	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 11:51AM	D	Interdependent	
APCo_VA_00251	7905 S. Fork Rd, Pound VA 24279	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 4:22PM	E	Interdependent	
APCo_VA_00252	7905 S. Fork Rd, Pound VA 24279	Solar	3 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	9/22/2023 4:38PM	F	Interdependent	
APCo_VA_00253	Old Giles Rd, Dublin, VA 24084	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/2023 5:39PM	D	Interdependent	
APCo_VA_00254	Old Giles Rd, Dublin, VA 24084	Solar	3 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/2023 6:04PM	E	Interdependent	
APCo_VA_00255	Old Giles Rd, Dublin, VA 24084	Solar	2 MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/3/23 6:24PM	F	Interdependent	
APCo_VA_00256	Sarvis Rd, Pound, VA 24279	Solar	2.5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	10/16/2023 3:22PM	G	Interdependent	
APCo_VA_00257	364 State Rte 680, Nickelsville, VA	Solar	5 MW	Copper Ridge/138-12.47 kV, 25 MVA	Nickelsville 12.47 kV	10/18/2023 10:20AM	B	Active	
APCo_VA_00258	428 Flint Den Ln, Duffield, VA 24244	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/19/2023 4:25PM		Active	
APCo_VA_00259	428 Flint Den Ln, Duffield, VA 24244	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/20/2023 2:39PM		Active	
APCo_VA_00260	2540 N. Hazel Mtn Rd, Dante, VA 24237	Solar	4.375 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	10/22/2023 10:13AM		Withdrawn	
APCo_VA_00261	Roaring Frk Rd, Trammel, VA 24237	Solar	4.375 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	10/22/2023 10:16AM		Withdrawn	
APCo_VA_00262	6347 Rye Cove Mem. Rd, Duffield, VA 24244	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 1:40PM		Interdependent	
APCo_VA_00263	Flint Den Ln, Duffield, VA 24244	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 2:22PM		Interdependent	
APCo_VA_00264	6347 Rye Cove Mem. Rd, Duffield, VA 24244	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	10/30/2023 2:28PM		Interdependent	

APCo_VA_00265	6347 Rye Cove Mem. Rd, Duffield, VA 24244	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	11/1/2023 5:09PM		Interdependent	
APCo_VA_00266	941 Eagle Springs Rd, Danville, VA	BESS	10 MW	East Danville, 69-12.47 kV, 8.4 MVA	Lorillard 12.47 kV	11/16/2023 11:33AM	A	Active	
APCo_VA_00267	941 Eagle Springs Rd, Danville, VA	BESS	20 MW	East Danville, 69-12.47 kV, 8.4 MVA	Lorillard 12.47 kV	11/16/2023 11:33AM	B	Active	
APCo_VA_00268	766 Margie Lawson Ln, Nora, VA 24272	Solar	5 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/04/2023 6:24PM	A	Active	
APCo_VA_00269	766 Margie Lawson Ln, Nora, VA 24272	Solar	5 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/05/2023 10:34AM	B	Active	
APCo_VA_00270	766 Margie Lawson Ln, Nora, VA 24272	Solar	3 MW	Neece Creek 69-12.47 kV, 8.4 MVA	Neece Creek 12.47 kV	12/05/2023 5:00PM	C	Interdependent	
APCo_VA_00271	555 Authority Dr, Christiansburg, VA 24073	Solar	3 MW	Hans Meadow 69-12.47 kV, 25 MVA	Market Place 12.47 kV	1/24/2024 11:38AM	A	Active	
APCo_VA_00272	738 Jakes Branch Rd, Clintwood, VA 24228	Solar	5 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV	1/26/2024 3:00PM	A	Active	
APCo_VA_00273	738 Jakes Branch Rd, Clintwood, VA 24228	Solar	5 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV	1/26/2024 3:09PM	B	Active	
APCo_VA_00274	738 Jakes Branch Rd, Clintwood, VA 24228	Solar	3 MW	Clintwood 69-12.47 kV, 20 MVA	Georges Fork 12.47 kV		C	Active	
APCo_VA_00275	Izaak Walton Rd, Madison Heights, VA	Solar	4 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	3/20/2024 9:36AM	B	Active	
APCo_VA_00276	Izaak Walton Rd, Madison Heights, VA	Solar	3 MW	Monroe/69-12.47 kV, 20 MVA	Coolwell 12.47 kV	3/20/2024 9:39AM	C	Interdependent	
APCo_VA_00277	-82.7643, 36.7265	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:33AM	A	Active	
APCo_VA_00278	-82.7643, 36.7265	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Duffield 12.47	3/24/2024 9:37AM	B	Active	
APCo_VA_00279	-82.7643, 36.7266	Solar	4.8 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:37AM	C	Interdependent	
APCo_VA_00280	-82.7643, 36.7267	Solar	14.5 MW	Sunbright 138-12.47 kV, 25MVA	Route 23 12.47 kV	3/24/2024 9:49AM	D	Interdependent	
APCo_VA_00281	-81.602266, 36.675795	BESS	5.988 MW	Glade 69-34.5 kV, 30 MVA	Whitotop	3/27/2024 10:40AM	A	Active	
APCo_VA_00282	-81.551817, 36.606223	BESS	2.994 MW	Glade 69-34.5 kV, 30 MVA	Whitotop	3/27/2024 10:40AM	B	Active	
APCo_VA_00283	-82.562928, 37.146331	Solar	5 MW	Pound 69-34.5 kV, 25 MVA	Indian Creek 34.5 kV	3/28/2024 8:48AM	H	Interdependent	
APCo_VA_00284	-82.269216, 37.007415	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:50AM	A	Active	
APCo_VA_00285	-82.269216, 37.007415	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	3/28/2024 8:52AM	B	Active	
APCo_VA_00286	-82.269216, 37.007415	Solar	4.4 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:52AM	C	Interdependent	
APCo_VA_00287	-82.269216, 37.007415	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Wakenva 12.47 kV	3/28/2024 8:52AM	D	Interdependent	
APCo_VA_00288	-82.269216, 37.007415	Solar	9 MW	Trammel 69 kV-12.47 kV, 6.25MVA	Dante 12.47 kV	3/28/2024 8:52AM	E	Interdependent	
APCo_VA_00289	-79.097197, 37.439909	Solar	2.5 MW	Gomingo 138-12.47 kV, 20 MVA	Amelon 12.47 kV	3/29/2024 9:15AM	A	Active	
APCo_VA_00290	-79.097197, 37.439909	Solar	2 MW	Mount Union 69-12.47 kV, 20 MVA	Etzler Road 12.47 kV	3/29/2024 9:15AM	A	Active	
APCo_VA_00291	36.873701, -81.325924	Solar	5 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.5 kV	4/10/24 9:40AM		Withdrawn	
APCo_VA_00292	36.873701, -81.325924	Solar	5 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.5 kV	4/10/24 9:40AM		Withdrawn	
APCo_VA_00293	36.873701, -81.325924	Solar	3 MW	Rural Retreat 138-34.5 kV, 20 MVA	Groseclose 34.3 kV	4/10/24 9:41AM		Withdrawn	
APCo_VA_00294	36.940937, -82.04998	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/10/24 9:41AM	A	Active	
APCo_VA_00295	36.940824, -82.050072	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	B	Active	
APCo_VA_00296	36.940937, -82.04998	Solar	3 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	C	Interdependent	
APCo_VA_00297	36.940937, -82.04998	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	D	Interdependent	
APCo_VA_00298	36.940824, -82.050072	Solar	5 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/24 8:56AM	E	Interdependent	
APCo_VA_00299	36.940824, -82.050072	Solar	3 MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	4/11/2024 9:48AM	F	Interdependent	
APCo_VA_00300	36.62163772, -81.23289647	Solar	9 MW	Independence 69-34.5 kV, 20 MVA	Rural 34.5 kV	4/24/2024 8:48AM		Withdrawn	
APCo_VA_00301	36.6586, -79.9522	Solar	5 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	5/9/2024 9:19AM	C	Interdependent	
APCo_VA_00302	36.658373, -79.95541	Solar	2 MW	Fieldale 138-34.5 kV, 30 MVA	Carver 34.5 kV	6/24/2024 9:39AM	D	Interdependent	
APCo_VA_00303	-82.6650662428, 36.7704842288	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	6/28/2024 9:29AM	A	Interdependent	
APCo_VA_00304	-82.6650662428, 36.7704842288	Solar	4 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	6/28/2024 9:30AM	B	Interdependent	
APCo_VA_00305	-82.6650662428, 36.7704842288	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	6/28/2024 9:32AM	C	Interdependent	
APCo_VA_00306	-82.6650662428, 36.7704842288	Solar	3 MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	6/28/2024 9:33AM	D	Interdependent	
APCo_VA_00307	-80.2348, 36.5665	Solar	5 MW	Stuart 69-34.5 kV, 30 MVA	Carroll 34.5 kV	7/25/2024 8:38AM	A	Active	
APCo_VA_00308	-80.241, 36.5641	Solar	5 MW	Stuart 69-34.5 kV, 30 MVA	Carroll 34.5 kV	7/25/2024 8:38AM	B	Active	
APCo_VA_00309	-81.722544, 36.786742	Solar	5 MW	Glade 69-34.5 kV, 30 MVA	Route 11 12.47 kV	7/28/2024 2:34PM	A	Active	
APCo_VA_00310	-79.826386, 37.10375	Solar	3 MW	Blaine 138-34.5 kV, 30 MVA	Burnt Chimney 34.5 kV	8/4/2024 2:47PM	B	Active	
APCo_VA_00311	-79.826386, 37.10375	Solar	3 MW	Blaine 138-34.5 kV, 30 MVA	Burnt Chimney 34.5 kV	8/4/2024 2:52PM	C	Interdependent	
APCo_VA_00312	-79.826386, 37.10375	Solar	3 MW	Blaine 138-34.5 kV, 30 MVA	Burnt Chimney 34.5 kV	8/4/2024 2:52PM	D	Interdependent	
APCo_VA_00313	-79.754244, 37.499247	Solar	5MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 3:33PM	A	Active	
APCo_VA_00314	-79.754244, 37.499247	Solar	5MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 3:542PM	B	Active	
APCo_VA_00315	-79.754244, 37.499247	Solar	5MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 4:10PM	D	Interdependent	
APCo_VA_00316	-79.754244, 37.499247	Solar	3 MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 3:54PM	C	Interdependent	
APCo_VA_00317	-79.754244, 37.499247	Solar	5 MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 4:10PM	E	Interdependent	
APCo_VA_00318	-79.754244, 37.499247	Solar	3 MW	Wheatland/69-12.47 kV, 20 MVA	Mill Creek 12.47 kV	8/4/2024 4:10PM	F	Interdependent	
APCo_VA_00319	-79.753338, 37.063487	Solar	3MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	8/4/2024 4:35PM	B	Active	
APCo_VA_00320	-79.753338, 37.063487	Solar	3MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	8/4/2024 4:35PM	C	Interdependent	
APCo_VA_00321	-79.753338, 37.063487	Solar	2MW	Westlake 138-34.5 kV, 30 MVA	Dudley 34.5 kV	8/4/2024 4:53PM	D	Interdependent	

APCo_VA_00322	-79.80762098, 37.52471957	Solar	5MW	Wheatland/69-12.47 kV, 20 MVA	Springwood 12.47 kV	8/4/2024 5:51PM	G	Interdependent	
APCo_VA_00323	-79.80762098, 37.52471957	Solar	5MW	Wheatland/69-12.47 kV, 20 MVA	Springwood 12.47 kV	8/4/2024 5:56PM	H	Interdependent	
APCo_VA_00324	-79.80762098, 37.52471957	Solar	3MW	Wheatland/69-12.47 kV, 20 MVA	Springwood 12.47 kV	8/4/2024 5:56PM	I	Interdependent	
APCo_VA_00325	-80.70057389, 37.33514846	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/4/2024 6:06PM	A	Active	
APCo_VA_00326	-80.70057389, 37.33514846	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/4/2024 6:12PM	B	Active	
APCo_VA_00327	-80.70057389, 37.33514846	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/4/2024 7:31PM	C	Interdependent	
APCo_VA_00328	-80.70057389, 37.33514846	Solar	3MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/4/2024 7:53PM	D	Interdependent	
APCo_VA_00329	-80.70057389, 37.33514846	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/7/2024 9:50AM	E	Interdependent	
APCo_VA_00330	-80.70057389, 37.33514846	Solar	3MW	Kimballton 138-34.5 kV, 30 MVA	Route 100	8/7/2024 9:50AM	F	Interdependent	
APCo_VA_00331	-80.410729, 37.169942	Solar	2.5MW	Hans Meadow 69-12.47 kV, 25 MVA	Market Place 12.47 kV	8/7/2024 10:29AM	B	Active	
APCo_VA_00332	-80.410729, 37.169942	Solar	3 MW	Hans Meadow 69-12.47 kV, 25 MVA	Market Place 12.47 kV	8/7/2024 10:29AM	C	Interdependent	
APCo_VA_00333	-82.674639, 36.760861	Solar	4MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	8/7/2024 11:37AM	E	Interdependent	
APCo_VA_00334	-82.674639, 36.760861	Solar	4MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	8/7/2024 11:46AM	F	Interdependent	
APCo_VA_00335	-82.674639, 36.760861	Solar	3MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	8/7/2024 11:47AM	G	Interdependent	
APCo_VA_00336	-82.674639, 36.760861	Solar	3MW	Hill 138 kV, 12.47 kV, 8.4MVA	Fort Blackmore 12.47 kV	8/7/2024 11:47AM	H	Interdependent	
APCo_VA_00337	-81.71129, 36.91042	Solar	5MW	Saltville 138-34.5 kV, 20MVA	North Holston 34.5 kV	8/8/2024 10:52AM		Withdrawn	
APCo_VA_00338	-81.46256572, 37.16732113	Solar	3MW	Buchorn 138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	8/14/2024 2:28PM	B	Active	
APCo_VA_00339	-81.46256572, 37.16732113	Solar	3MW	Buchorn 138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	8/14/2024 2:28PM	C	Interdependent	
APCo_VA_00340	-81.46256572, 37.16732113	Solar	2MW	Buchorn 138-34.5 kV, 30MVA	Bluefield Rd. 34.5 kV	8/14/2024 2:28PM	D	Interdependent	
APCo_VA_00341	-80.678475, 37.371144	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Pembroke 34.5 kV	8/14/2024 2:59PM	A	Active	
APCo_VA_00342	-80.678475, 37.371144	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Pembroke 34.5 kV	8/14/2024 2:59PM	B	Active	
APCo_VA_00343	-80.678475, 37.371144	Solar	5MW	Kimballton 138-34.5 kV, 30 MVA	Pembroke 34.5 kV	8/14/2024 2:59PM	C	Interdependent	
APCo_VA_00344	-79.968259, 37.000684	Solar	4MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	8/15/2024 7:39AM	B	Active	
APCo_VA_00345	-79.968259, 37.000684	Solar	4MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	8/15/2024 7:41AM	C	Interdependent	
APCo_VA_00346	-79.968259, 37.000684	Solar	3MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	8/15/2024 7:42AM	D	Interdependent	
APCo_VA_00347	-81.817456, 37.013511	Solar	5MW	Claypool Hill 138-12.47 kV, 25 MVA	Wardell 12.47 kV	8/30/2024 9:12AM	A	Active	
APCo_VA_00348	-79.183794, 37.52355	Solar	3MW	Abert 69-12.47 kV, 22.4 MVA	High Peak 12.47 kV	9/2/2024 9:01AM	A	Active	
APCo_VA_00349	-82.112039, 36.899185	Solar	5MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	9/26/2024 9:26AM	G	Interdependent	
APCo_VA_00350	-82.112039, 36.899185	Solar	5MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	9/26/2024 9:26AM	H	Interdependent	
APCo_VA_00351	-82.112039, 36.899185	Solar	3MW	Lebanon 138-12.47 kV, 22.4 MVA	Cleveland 12.47 kV	9/26/2024 9:26AM	I	Interdependent	
APCo_VA_00352	-79.669468, 36.730892	Solar	2MW	Stockton/ 138-34.5 kV, 30 MVA	Sandy River 34.5 kV	10/3/2024 8:52AM	B	Active	
APCo_VA_00353	-79.121772, 37.277877	Solar	5MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	10/7/2024 7:43AM	B	Active	
APCo_VA_00354	-79.121772, 37.277877	Solar	5MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	10/7/2024 7:45AM	C	Interdependent	
APCo_VA_00355	-79.121772, 37.277877	Solar	3MW	Rustburg/138-12.47 kV, 20 MVA	Willow Lake 12.47 kV	10/7/2024 7:48AM	D	Interdependent	
APCo_VA_00356	-79.882239, 37.467751	Solar	5MW	Trinity 69-12.47 kV, 25 MVA	Fincastle 12.47 kV	10/21/2024 2:38PM	A	Active	
APCo_VA_00357	-79.882239, 37.467751	Solar	5MW	Trinity 69-12.47 kV, 25 MVA	Fincastle 12.47 kV	10/21/2024 2:38PM	B	Active	
APCo_VA_00358	-79.882239, 37.467751	Solar	3MW	Trinity 69-12.47 kV, 25 MVA	Fincastle 12.47 kV	10/21/2024 2:38PM	C	Interdependent	
APCo_VA_00359	-79.930221, 36.9794106	Solar	5MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	10/25/2024 1:28PM	E	Interdependent	
APCo_VA_00360	-79.930221, 36.9794106	Solar	5MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	10/25/2024 1:32PM	F	Interdependent	
APCo_VA_00361	-79.930221, 36.9794106	Solar	3MW	Franklin 138-34.5 kV, 30 MVA	Retreat 34.5 kV	10/25/2024 1:36PM	G	Interdependent	
APCo_VA_00362	-82.0148095555, 37.1640530948	Solar	5MW	Garden Creek 69-12.34 kV, 22.4 MVA	Page 12.47 kV	10/30/2024 5:39PM	A	Active	
APCo_VA_00363	-80.67269, 36.786038	Solar	3.5MW	Huffman 138-34.5 kV, 3 0MVA	Dugspur 34.5 kV	10/31/2024 10:19AM	A	Active	
APCo_VA_00364	-80.276508, 36.992593	Solar	4.5MW	Floyd 138-12.47kV, 10.5MVA	Terry's Fork 12.47 kV	10/31/2024 12:12PM	A	Active	
APCo_VA_00365	-80.68925, 37.110694	Solar	3MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/31/2024 1:14PM	G	Interdependent	
APCo_VA_00366	-80.68925, 37.110695	Solar	3MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/31/2024 1:18PM	H	Interdependent	
APCo_VA_00367	-80.68925, 37.110696	Solar	2MW	Dublin 34.5-12.47 kV, 9.4 MVA	Town 12.47 kV	10/31/2024 1:26PM	I	Interdependent	
APCo_VA_00368	-79.947017, 36.943528	Solar	5MW	Franklin 138-34.5 kV, 30 MVA	Ferrum 34.5 kV	11/3/2024 6:31PM	H	Interdependent	
APCo_VA_00369	-79.947017, 36.943528	Solar	5MW	Franklin 138-34.5 kV, 30 MVA	Ferrum 34.5 kV	11/3/2024 6:57PM	I	Interdependent	
APCo_VA_00370	-79.947017, 36.943528	Solar	3MW	Franklin 138-34.5 kV, 30 MVA	Ferrum 34.5 kV	11/3/2024 6:37PM	J	Interdependent	
APCo_VA_00371	-78.614006, 37.874661	Solar	2.4 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	11/4/2024 12:06PM	D	Interdependent	
APCo_VA_00372	-78.614006, 37.874661	Solar	2.4 MW	Esmont 46-12.47 kV, 4.69 MVA	Esmont 12.47 kV	11/4/2024 12:06PM	E	Interdependent	
APCo_VA_00373	-79.814333, 36.547833	Solar	5 MW	Ridgeway 138-34.5 kV, 25 MVA	Mason Heights 12.47 kV	12/18/2024 3:33PM	B	Active	
APCo_VA_00374	-79.814333, 36.547834	Solar	5 MW	Ridgeway 138-34.5 kV, 25 MVA	Mason Heights 12.47 kV	12/18/2024 3:33PM	C	Interdependent	
APCo_VA_00375	-79.814333, 36.547835	Solar	3 MW	Ridgeway 138-34.5 kV, 25 MVA	Mason Heights 12.47 kV	12/18/2024 3:33PM	D	Interdependent	

Xfmr MVA is max nameplate rating, although distribution station transformer loading shall be limited to 90% of their normal seasonal capability rating.

Withdrawn
Active

In Service